

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT

State of Washington Date Printed: 20-Nov-2007 Log No. 0
 Construction / Decommission: Original Construction Notice 283578
Construction

CURRENT

Notice of Intent No.: WEO7285

Unique Ecology Well I.D. No ALN897

Water Right Permit Number:

OWNER: **BEEDLES, RON & CATHERIN**

OWNER ADD **2525 SOUTH REBECCA STREET
SPOKANE, WA 99223**

Well Add **2876 DEEP LAKE S. SHORE**

City: **Colville, WA 99114**

County: **Stevens**

Location **SE 1/4 SW 1/4 Sec 27 T 39 R 41E EW**

Lat/Long: Lat Deg Lat Min/Sec
 (s, t, r still)

REQUIRED) Long Deg Long Min/Sec

Tax Parcel No.: **5679820**

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well) **1**
NEW WELL Method: **ROTARY**

DIMENSIONS Diameter of well: **6** inches
 Drilled **180** ft. Depth of completed well **180** ft.

CONSTRUCTION DETAILS: Casing installed **WELDED**
 Liner installed: **PVC**
4 " Dia fro **20** ft. to **180** ft.
6 " Dia fro **+2** ft. to **29** ft.
 " Dia fro ft. to ft.
 " Dia fro ft. to ft.

Perforations: Yes Used In: **LINER**
 Type of perforator used **SKILL SAW**
 SIZE of perforation **1/8** in. b **7** in.
80 Perforation from **60** ft. to **180** ft.
 Perforation from ft. to ft.
 Perforation from ft. to ft.

Screens: No K-Pac Location
 Manufacture's Name
 Type: Model No
 Diam. slot size from ft. to ft.
 Diam. slot size from ft. to ft.

Gravel/Filter packed: No Size of Gravel
 Material placed fro ft. to ft.

Surface seal: Yes To what depth **19** ft.
 Seal method: Material used in seal **BENTONITE**
 Did any strata contain unusable water **No**
 Type of water Depth of strat
 Method of sealing strata off

PUMP: Manufacture's name
 Type: H.P. **0**

WATER LEVELS Land-surface elevation above mean sea level: **0** ft.
 Static level **33** ft. below top of well Date **09/19/2007**
 Artesian Pressure lbs per square inch Date
 Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.
 Was a pump test made **No** If yes, by whom
 Yield gal/min wit ft drawdown after
 Yield gal/min wit ft drawdown after
 Yield gal/min wit ft drawdown after
 Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)
 Time: Water Level Time: Water Level Time: Water Level

 Date of test:
 Bailer test gal/mi ft drawdown after hrs.
 Air tes **4-5** gal/min w/ stem set at **180** ft. for **1** hours
 Artesian flow gpm Date
 Temperature of water Was a chemical analysis made **No**

CONSTRUCTION OR DECOMMISSION PROCEDURE
 Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
CLAY BROKEN SHALE BLACK	0	24
BLACK SHALE SOFT	24	63
FRAC W/WATER	63	66
BLACK SHALE MED	66	143
BLACK SHALE W/QUARTZ	143	180

RECEIVED

JAN 02 2008

DEPARTMENT OF ECOLOGY
EASTERN REGIONAL OFFICE

Notes:

Work starts **09/18/2007** Complete **09/19/2007**

WELL CONSTRUCTION CERTIFICATION:
 I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief
 Driller Engineer Trainee

Name: **ANDY BAKER** License No.: **2892T**
 Signature: *Andy Baker*

If trainee, Licensed driller is: **ROD FOGLE** License No.: **1194**
 Licensed Driller Signature *Rod Fogle*

Drilling Company:
 NAME: **FOGLE PUMP & SUPPLY, INC.**
 ADDRESS: **316 W. 5TH
Colville, WA 99114**
 Phone: **509-684-2569** Toll Free: **800-533-6518**
 E-Mail: **jeanne@foglepump.com**
 FAX: **509-684-3032** WEB Site: **www.foglepump.com**
 Contractor's
 Registration No.: **FOGLEPS095L4** Date Log Created: **11/06/2007**

