

WATER WELL REPORT

State of Washington Date Printed: 23-Nov-2015 Log No. 0
 Construction / Decommission: Original
 Construction Construction Notice

CURRENT
 Notice of Intent No.: WE20724
 Unique Ecology Well I.D. No: BAT739
 Water Right Permit Number:
 OWNER: STOTTS, JOHN

OWNER ADD 17320 HWY 21 W
 MALO, WA 99150

Well Add 17320 HWY 21 W
 City: Malo, WA 99150 County: Ferry
 Location: NE 1/4 NW 1/4 Sec 22 T 38 R 33 EW
 Lat/Long: Lat Deg Lat Min/Sec
 (s, t, r still) Long Deg Long Min/Sec
 REQUIRED)
 Tax Parcel No.: 33822210002100

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well)
 DEEPEMED Method: ROTARY

DIMENSIONS: Diameter of well: 6 inches
 Drilled 31 ft. Depth of completed well 98 ft.

CONSTRUCTION DETAILS: Casing installed WELDED
 Liner installed: 6 " Dia from +2 ft. to 98 ft.
 " Dia from ft. to ft. " Dia from ft. to ft.
 " Dia from ft. to ft. " Dia from ft. to ft.

Perforations: No Used In:
 Type of perforator used
 SIZE of perforations in. by in.
 Perforations from ft. to ft.
 Perforations from ft. to ft.
 Perforations from ft. to ft.

Screens: 1 K-Pac Location: 90
 Manufacture's Name JOHNSON
 Type: STAINLESS Model No
 Diam. 6 slot size: 14 from 93 ft. to 98 ft.
 Diam. slot size: from ft. to ft.

Gravel/Filter packed: No Size of Gravel
 Material placed fro ft. to ft.

Surface seal: Yes To what depth 19 ft.
 Seal method: Material used in seal PREV DRILLED
 Did any strata contain unusable water No
 Type of water Depth of strata
 Method of sealing strata off

PUMP: Manufacture's name
 Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.
 Static level 29 ft. below top of well Date 07/28/2015
 Artesian Pressure lbs per square inch Date
 Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.
 Was a pump test made No If yes, by whom
 Yield: gal/min with ft drawdown after
 Yield: gal/min with ft drawdown after
 Yield: gal/min with ft drawdown after
 Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level

| | | | | | |
|-------|-------------|-------|-------------|-------|-------------|
| Time: | Water Level | Time: | Water Level | Time: | Water Level |
| | | | | | |
| | | | | | |
| | | | | | |

 Date of test:
 Bailer test gal/min ft drawdown after hrs.
 Air test 50 gal/min w/ stem set at 95 ft. for 1 hours
 Artesian flow gpm Date
 Temperature of water Was a chemical analysis made No

CONSTRUCTION OR DECOMMISSION PROCEDURE
 Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

| Material | From | To |
|-----------------------------|------|----|
| SAND BROWN MED SOME GRAVELS | 67 | 73 |
| SAND SILT BROWN WATER | 73 | 90 |
| SAND BRN CRS WATER | 90 | 98 |

RECEIVED

DEC 14 2015

Notes: Department of Ecology
 Eastern Washington Office

Work starts 07/27/2015 Complete 07/28/2015

WELL CONSTRUCTION CERTIFICATION:
 I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

Driller Engineer Trainee
 Name: JON RICARD License No.: 2341
 Signature: *J Ricard*

If trainee, Licensed driller is: License No.:
 Licensed Driller Signature

Drilling Company:
 NAME: FOGLE PUMP & SUPPLY, INC. Shop: REPUBLIC
 ADDRESS: PO Box 456
 Republic, WA 99166
 Phone: 5097752878 Toll Free: 8008453500
 E-Mail: bree@foglepump.com
 FAX: 5097750498 WEB Site: www.foglepump.com
 Contractor's
 Registration No.: FOGLEPS095L4 Date Log Created: 11/23/2015

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report