

WATER WELL REPORT

STATE OF WASHINGTON

Application No _____

Permit No _____

(1) OWNER: Name H. Max Skinner Address Route 1, Box 163, Chewelah, WA 99109

LOCATION OF WELL: County STEVENS NW 1/4 NW 1/4 Sec. 6 T. 32 N. R. 40E W.

bearing and distance from section or subdivision corner _____

(3) PROPOSED USE: Domestic Industrial Municipal
 Irrigation Test Well Other

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
 New well Method: Dug Bored
 Deepened Cable Driven
 Reconditioned Rotary Jetted

(5) DIMENSIONS: Diameter of well 6 inches.
 Drilled 63 ft. Depth of completed well 59 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 1 ft. to 59 ft.
 Threaded " Diam. from _____ ft. to _____ ft.
 Welded " Diam. from _____ ft. to _____ ft.

Perforations: Yes No
 Type of perforator used _____
 SIZE of perforations _____ in. by _____ in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

Screens: Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes No To what depth? 30 ft.
 Material used in seal bentonite
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
 Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation _____ ft.
 Static level 35 ft. below top of well Date 11/11/85
 Artesian pressure _____ lbs. per square inch Date _____
 Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? _____
 Yield: 10+ gal./min. with _____ ft. drawdown after _____ hrs.

ESTIMATED AIRLIFTE

Time	Water Level	Time	Water Level	Time	Water Level

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)
 Date of test _____
 Bailor test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation

MATERIAL	FROM	TO
Top soil	0	2
Sand, fine	2	12
Clay, brown, hard pan	12	18
Sand, brown, fine	18	42
Sand, gravel & gray silt	42	52
Sand & gravel w/water	52	62
Granite, gray, hard	62	63

NO PVC Liner Installed

6" Drive shoe installed

RECEIVED

DEC 8 1985

DEPARTMENT OF ECOLOGY
 SPOKANE REGIONAL OFFICE

Work started 11/11, 19 85 Completed 11/11, 19 85

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME CONDOROSA DRILLING & DEVELOPMENT, INC.
 (Person, firm, or corporation) (Type or print)

Address E. 6010 Broadway, Spokane, WA 99212

(Signed) Douglas E. Lane
 Douglas E. Lane (Well Driller)

License No. 1030 Date 11/11, 19 85

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

12/9/85 *[Signature]*